

# Firestone

BUILDING PRODUCTS COMPANY

Please submit copy of letter with Pre-Installation Notice

August 8<sup>th</sup>, 2008

Michael DiStefano  
Continental Materials, Inc.  
1614 Old York Rd.  
Abington, PA 19001

Re: Continental Materials, Inc. - Asphalt

Mr. DiStefano,

Thank you for your inquiry regarding the use of Continental Materials Asphalt products in Firestone roofing assemblies. Firestone accepts Continental Materials Type III or Type IV asphalt that has been tested and passed the standards set forth by ASTM D-312. According to Continental Materials website, located at [www.continentalmaterials.com](http://www.continentalmaterials.com), both the standard and No Smell™ asphalt products have been tested in accordance, and passed, ASTM D-312. With that Firestone would accept both the Type III or Type IV products, depending on Firestone's specification and installation, in the Roofing System where applicable. Please refer to the Red Shield Warranty for specific warranty coverage(s) and limitations.

Please refer to the current Firestone Roofing Systems Technical Specifications Database, on our web site [www.firestonebpco.com](http://www.firestonebpco.com), for detailed assembly information and requirements. If you have any questions, or require further assistance, please contact me at 1-800-428-4511, ext. 57273

Sincerely, Firestone Building Products

Allen M. Sopko  
Roof Systems Solutions  
Roof Solutions Manager  
sopkoallen@firestonebp.com  
P: 1-800-428-4511  
F: 317-428-5872

cc: Carter Slusher

## **NOBODY COVERS YOU BETTER**

310 East 96<sup>th</sup> Street • Indianapolis, IN 46240 • 317-575-7000  
Technical Hotline 1-800-428-4511 • Facsimile: 1-800-242-0504